

Technical Department

If There's No Water Kill the Fire

Illustrations Furnished Through Courtesy
of the Interstate Commerce Commission

By J. E. BJORKKHOLM*

Superintendent of Motive Power,
Chicago, Milwaukee, St. Paul and Pacific R.R. Co.

if not entirely eliminatd, these wholly
unnecessary calamities.

The matter of boiler explosions is
a comprehensive subject. Numerous
and voluminous reports have
been written and much costly re-
search has been undertaken, and I
believe it is generally recognized
that, from the point of view of
proper material, adequate construc-
tion and dependable appurtenances,
the boiler as a pressure vessel is sur-
rounded by the necessary factors of
safety if properly operated. The
human element entering into the
question, however, has not in my
opinion been given the consideration
it deserves and that feature will be
discussed in this article.

I think it is universally accepted
that few other types of boilers are
subject to the abuse and difficulties
surrounding the operation of loco-
motive boilers. It is to the everlast-
ing credit of the men who design
and build them, to the men who
maintain them and to the men who
operate them that, with few excep-

in good condition—but still the dis-
coloring area of the crown sheet gives
indisputable evidence as to the di-
rect cause of the accident.


Through its activities the Bureau
of Locomotive Inspection has done
excellent work since it was estab-
lished in reducing these accidents.
The railroads likewise have endeav-
ored, through improved material,
certain safety devices, better design
and maintenance practices and safety
first activities, to prevent these ca-
strophes which leave in their wake
death, sorrow and painful injuries
that frequently result in life-long
disabilities, to say nothing about the
usually large material loss involved;
yet they occur.

What is the answer? In this ar-
ticle the writer will attempt to ap-
proach the subject from an angle
which in his opinion has heretofore
not been fully explored. It is hoped
that the expressions herein set forth
may cause serious thought and re-
flection so that in the end they may
bring forth action tending to reduce,

WAS found that the accident
was caused by overheating of
the crown sheet due to low
water." This statement is usually
the conclusion reached by the inspec-
tors of the Interstate Commerce
Commission Bureau of Locomotive
Inspection who are always called
upon to investigate and report their
findings in connection with these
accidents, commonly referred to as
boiler explosions or crown sheet
failures.

The whys and the wherefores,
however, in most instances, remain
a mystery, as those who could throw
some light on the subject usually
become fatalities and only through
circumstantial evidence painstakingly
gathered by these trained in-
vestigators can some probable cause
be construed. In many instances
probable contributing factors are
mentioned; in others, no such fac-
tors are apparent and the boiler and
all its appurtenances are found to be

* Brother Bjorkholm has been a member of
Lodge 139 of our Brotherhood for many years.



One employe was fatally injured and two employes were seriously injured in this accident caused by overheating of the crown sheet due to low water. The explosion occurred while the locomotive was hauling a troop train at an estimated speed of 50 miles per hour.


In all the ramifications incidental to this type of accident the contribution made towards this unfortunate record although too frequently is due to various reasons, to reach an unsafe level without the crew in charge resorting to the only safe preventive, and instead taking a chance beyond a safe margin.

If the lesson can be brought home to engineers with low water, that it is far better to be up the railroad than to take a chance with low water, pointing out to them possible terms never to take a chance

On the Milwaukee the mechanical state Commerce Commission has issued a ruling that the Commission will be publishing a list of the best practices to be followed by the

management for a period of years has resorted to making urgent appeals to engineers in the strongest possible terms never to take a chance with low water, pointing out to them that if necessary, in order to be safe, it is better to be up the railroad than

to take a chance with low water, pointing out to them that if necessary, in order to be safe, and by a large margin. Frequent educational notices or bulletins are posted on bulletin boards reserved exclusively for this purpose, thus not permitting mixed with bulletins on various other subjects, but to stand alone and conspicuous in their importance. In them attention is usually called to accidents or difficulties due to low water, whether on the home property or on other carriers, pointing out briefly the causes and consequences and



The result of an explosion caused by warping of the box sheet during the trial, together with the date of the explosion, the reason of the explosion, the number of employees who were seriously injured, and the number of employees who were killed, is being investigated by the State Commerce Commission. The trial was held at the Milwaukee

to many engineers. In their service as such, in many cases stretching over scores of years, they have taken a lot of chances with low water and, unlike betting on the horses, in most cases they have won but eventually the time comes when they take one chance too many. This is no criticism of the engineer. It is only a consequence, especially after their having operated a locomotive for years, often perhaps under trying conditions. There have been many occasions when things looked pretty dark but finally they succeeded in correcting whatever trouble was confronting them and the situation was cleared up.

This, together with the ingrained pride of most engineers to bring their trains in on time and the apathy of most of them to make a statement or, as they usually express it, "to write a letter," causes them to try to keep going even when the odds seem overwhelmingly against them. In most instances they win, in many others they lose; but in some cases they are not left alive. In this connection, may I say that I have the highest regard for engineers who are resourceful and willing to take a chance—except when taking a chance with low water.

It is not the intention in the foregoing to infer that the cause of boiler explosions in all cases is due to engineers permitting the water to reach an unsafe level and failing to take the only precaution that can be taken under the circumstances. I have merely aimed to elaborate on a cause which in my opinion has not been given the important attention it deserves. I do mean, however, that

ing a chance with low water. It is not the intention in the foregoing to infer that the cause of boiler explosions in all cases is due to engineers permitting the water to reach an unsafe level and failing to take the only precaution that can be taken under the circumstances. I have merely aimed to elaborate on a cause which in my opinion has not been given the important attention it deserves. I do mean, however, that

ing a chance with low water. It is not the intention in the foregoing to infer that the cause of boiler explosions in all cases is due to engineers permitting the water to reach an unsafe level and failing to take the only precaution that can be taken under the circumstances. I have merely aimed to elaborate on a cause which in my opinion has not been given the important attention it deserves. I do mean, however, that

ing a chance with low water. It is not the intention in the foregoing to infer that the cause of boiler explosions in all cases is due to engineers permitting the water to reach an unsafe level and failing to take the only precaution that can be taken under the circumstances. I have merely aimed to elaborate on a cause which in my opinion has not been given the important attention it deserves. I do mean, however, that

ing a chance with low water. It is not the intention in the foregoing to infer that the cause of boiler explosions in all cases is due to engineers permitting the water to reach an unsafe level and failing to take the only precaution that can be taken under the circumstances. I have merely aimed to elaborate on a cause which in my opinion has not been given the important attention it deserves. I do mean, however, that

ing a chance with low water. It is not the intention in the foregoing to infer that the cause of boiler explosions in all cases is due to engineers permitting the water to reach an unsafe level and failing to take the only precaution that can be taken under the circumstances. I have merely aimed to elaborate on a cause which in my opinion has not been given the important attention it deserves. I do mean, however, that

Plate 2. Cars of burning gasoline ignited as a result of the explosion of the boiler shown in Plate 1.



It is an old saying that familiarity counts of his earthly doings to St. Peter. than be called upon to render an account of his earthly doings to St. Peter. than be called upon to render an account of his earthly doings to St. Peter. than be called upon to render an account of his earthly doings to St. Peter.


There is only one thing to do so they are playing with dynamite. should be, fully aware that in doing low water—even though as expert- ing at times to take chances with- level and result in an accident. How- ever, engineers and firemen are will- ing the water to reach an unsafe any reasonable excuse for permit- None of them, however, provides tors that eventually lead to disaster. pressure. These are the usual fac- for steam," to use a common ex- the locomotive crew to "trade water gured steam pressure and causing difficulties in maintaining the re- boilers foaming, etc., resulting in stokers, foreign matter in the coal, with water pumps, injectors and under packing, mechanical troubles leaky flues, defective valve and cyl- water level, such as inferior coal, the proper maintenance of a safe to cause difficulties occasionally in Many factors, however, conspire to cause difficulties occasionally in

to cause difficulties occasionally in Many factors, however, conspire to cause difficulties occasionally in Many factors, however, conspire to cause difficulties occasionally in Many factors, however, conspire to cause difficulties occasionally in

grates and after he noticed that the water was receding rapidly in the boiler he went over to the engineer's side and put on the engineer's injector while the engineer was busy looking ahead for signals, but did not take the trouble to satisfy himself whether the injector went to work or not."


"A reminder: Don't overlook frequently by trying the gage cocks, blowing out water gages and water columns and seeing that water gages are wide open."

I have always felt that the unfortunate experience of one might be a wholesome lesson to someone else and for that reason we publish, through the medium of these educational notices, unusual locomotive failures or accidents, without identifying the trains, locomotives or locomotive crews. It is our hope that in so doing others may profit. No matter what the subject may be, the closing paragraph of the notice is a



The result of an explosion caused by overheating of the crown sheet due to low water; one employe was killed and two employes were seriously injured in this accident. The explosion occurred while the locomotive was standing at a water crane; it had previously been cut off from a freight train about 4 1/2 miles from the water crane when it was found that it had run out of water.

"In this particular instance the trouble was due to the fireman forgetting that he had opened the ash pan swipes after he had shaken the



Interior of a firebox after an explosion caused by overheating of crown sheet due to low water. Three employes were killed and one employe and one non-employe were injured in this accident.


then making an urgent appeal, never to be guilty of operating a locomotive unless it is positively known that the water level is safe. Locomotive crews are instructed in plain and understandable language to extinguish the fire if in doubt, even though it may mean temporarily tying up the railroad. A few quotations are as follows:

"There is nothing new that I can say that has not already been said about the danger of low water. All I can do is to repeat what I have previously said. Don't take any chances with the water in the boiler. Check the water glass, water column and gage cocks together with the firebox and injectors or feedwater pumps when taking charge of an engine and remember that water is consumed at a rapid rate when a locomotive is working. Injectors and pumps might give trouble at times and if they do and the water gets low in the boiler you should extinguish the fire before you permit the water to reach a dangerous level, even though you may tip the railroad. A satisfactory explanation of the trouble with which you may have been confronted will not result in any criticism, but if you fail to take these precautions the most serious consequences usually are the result."

"Again let me say, don't take any chances with low water. If you have trouble keeping a safe water level take the precaution of extinguishing the fire before it is too late. If such precaution will cause any delay remember that it is better to have a delay on the side of safety than have a more serious delay a little later, and perhaps several fatalities with mourning families and friends."

already late. As will happen in rail-reading, and does happen when least expected, when he was a few miles out of town an air hose broke, stalled the train. As it seldom rains but what it pours on such occasions, he stalled in a sag and, to make a long story short, in his endeavor to get the train going after the air hose was fixed, he found himself in the predicament of being so short of water that he could not even make the next water tank turning light. He related the various attempts made in the interim to get water into the boiler; they are all familiar to most of us. He tried first one injector and then the other. The fireman then looked into the water cistern and found it as dry as the *Congressional Record*. The brakeman cut the engine off and the engineer tried to make the water tank, but as he stated, each mile seemed to be twice as long as ever before. When the lower gage cock began to register dry steam, although he had set, he decided it was time to follow the throttle open and brakes partly bulletin instructions, come what may. Subsequent inspection showed that he had not killed the fire one second too soon, as several radials would largely reduce the delay to his train, which for some reason was well baked.

Explosion caused by overheating of crown sheet due to low water. The boiler exploded while the locomotive was the second engine of a doubleheader hauling a freight train at an estimated speed of 15 miles per hour. The engineer was killed instantly, the fireman died about 6 hours after the accident, and the engineer and fireman of the leading locomotive, and the head brakeman who was riding in the cab of the leading locomotive, were seriously injured.




remainder in bold type never to take a chance with low water; each time somewhat different in language but in substance always the same.


Now I am not enough of an optimist to hope that these measures are going to save the Milwaukee entirely from these regrettable catastrophes. I know better because, unfortunately, we have had some regardless of these appeals. I am realistic enough to know that as long as there are engineers who, like the rest of us, are made of common clay and subject to human frailties we shall occasionally be confronted with these tragedies. I do know, on the other hand, however, that the assurance given engineers that they will have a friend in court, if I may use that expression, has caused them on several occasions to kill the loco-

motive and, incidentally, temporarily the up part of the railroad, before the critical moment, when the overheated crown sheet could no longer stand the pressure, arrived. Subsequent inspection revealed that had they waited only perhaps a few seconds longer the names of the crew would have been in the obituary column. (One incident, not unlike many others except in its detail, might be of interest:

(One morning, as I arrived at the office, I found an engineer waiting to see me. His worried look caused me to extend the somewhat dis-altogether unorthodox, greeting, particularly to an old acquaintance: "What the hell is riding you?" The freight the previous evening, on then related that while on a time



Pocket in a crown sheet, forward of the syphons, caused by overheating due to low water. Two employes were killed and one employe was injured in this accident.



Brotherhood of Locomotive Firemen and

The result of an explosion caused primarily by a collision in which the locomotive was derailed and came to rest leaning to the right with the front end down an embankment. This position caused parts of the firebox sheets to be bared of water which resulted in overheating. The explosion occurred about 10 minutes following the derailment—after the engineer, who had previously alighted on the ground, had returned to the locomotive in an apparent attempt to take measures to prevent the overheating of the exposed areas of the firebox. The engineer and one non-employee were killed and one employee and 21 non-employees were injured in this accident.

When he was through with his story I told him that naturally it was religiously observe the water level and if it is noticed the crews do not take them as well as the respective traveling engineers to task for not having instilled this important habit in their minds.

We know from experience that there is always a possibility of misreading the water level. There may be some strange reflection from the light illuminating the glass, causing a false level to be read; there may be a defective gasket causing a false level in the glass or there may be a pocket in a pipe; in short, there are many things that might cause a false level to appear. Therefore, it is of the utmost importance that the water glass and gage cocks be frequently tried.

Water in the boiler evaporates rapidly when the locomotive is worked to capacity and it does not take long for the water to reach an unsafe level when not replenished at the rate at which it is being consumed. There is no more important function for motive power officers and safety first supervisors than to

fail to be on the alert in observing and maintaining a safe water level. How the lack of alertness of a locomotive crew in this respect nearly caused a serious accident, far more serious than actually occurred, was vividly called to my attention a few years ago. I was aroused from a pleasant sleep in a Pullman one night by the porter, who handed me a message that a certain freight engine had had a crown sheet accident and at the next station secured more particulars, after which I obtained his section car and proceeded to the

The time element between the disappearance of the water in the bottom of the water glass and the critical moment the accident actually occurs depends, of course, on many factors, such as construction of the boiler, temperature of the fire, capacity at which the locomotive is being worked, nature of the track and whether any or no water is going into the boiler, etc. On the boiler, a very few minutes, surely not to exceed five or six, would permit the crown sheet to become red hot and at this temperature the tensile strength is reduced to only a few hundred pounds per square inch and the inevitable is bound to occur.

To sum up, everything that can possibly be done in the matter of design and maintenance of the boiler and boiler apparatus to keep them in the best possible mechanical condition, should always be considered the most important duties of

dynamic. The most important duty of road foremen and traveling engineers to perform while riding locomotives is to be sure that crews carefully observe these important functions, in traveling over the system I frequently enjoy rides on locomotives

When he was through with his story I told him that naturally it was religiously observe the water level and if it is noticed the crews do not take them as well as the respective traveling engineers to task for not having instilled this important habit in their minds.

We know from experience that there is always a possibility of misreading the water level. There may be some strange reflection from the light illuminating the glass, causing a false level to be read; there may be a defective gasket causing a false level in the glass or there may be a pocket in a pipe; in short, there are many things that might cause a false level to appear. Therefore, it is of the utmost importance that the water glass and gage cocks be frequently tried.

Water in the boiler evaporates rapidly when the locomotive is worked to capacity and it does not take long for the water to reach an unsafe level when not replenished at the rate at which it is being consumed. There is no more important function for motive power officers and safety first supervisors than to

fail to be on the alert in observing and maintaining a safe water level. How the lack of alertness of a locomotive crew in this respect nearly caused a serious accident, far more serious than actually occurred, was vividly called to my attention a few years ago. I was aroused from a pleasant sleep in a Pullman one night by the porter, who handed me a message that a certain freight engine had had a crown sheet accident and at the next station secured more particulars, after which I obtained his section car and proceeded to the

The time element between the disappearance of the water in the bottom of the water glass and the critical moment the accident actually occurs depends, of course, on many factors, such as construction of the boiler, temperature of the fire, capacity at which the locomotive is being worked, nature of the track and whether any or no water is going into the boiler, etc. On the boiler, a very few minutes, surely not to exceed five or six, would permit the crown sheet to become red hot and at this temperature the tensile strength is reduced to only a few hundred pounds per square inch and the inevitable is bound to occur.

To sum up, everything that can possibly be done in the matter of design and maintenance of the boiler and boiler apparatus to keep them in the best possible mechanical condition, should always be considered the most important duties of

those who have these matters in charge. After that is done, then crown sheet failures can be prevented only by enginemen always being on the alert in observing the water level. If for any reason a safe water level cannot be maintained there is only one thing to do and that is to kill the fire, the sooner the better.

Questions and Answers

The Air Brake

Answers by ROY J. KNAPP

2386. Air Brake Study.—"Although I have just started firing I am interested in learning all that I can about air brakes so that I will be able to pass examinations creditably. What in your opinion is the best method of doing this? I want to get started out right and avoid being confused, if possible."—D. S.

ANSWER.—We wish to congratulate you on your ambition and we are sure you will be well rewarded for your efforts.

Correspondence schools offer some very fine courses on air brakes and you can obtain literature from the manufacturers by writing their nearest office, advising the equipment you have in mind. We recommend that you do both and call on this department frequently.

2387. Triple Valves.—"Please name the different kinds of triple valves and explain the improvements made in later types."—Y. E.

ANSWER.—The developments in triple valves, starting in 1886 with the plain triple, are as follows:
1886—Plain triple for freight and passenger.
1888—H and P types quick action triples for freight and passenger.
1908—K type triple for freight, with quick service, retarded release, uniform recharge.
1908—L type quick action triple with quick service, graduated release, quick recharge, high brake cylinder pressure in emergency for passenger cars.
1912—Schedule UC with universal control valve. Improved passenger car brake for heavier cars and faster schedules, with the following improvements:
Maximum service stability and release sensitivity
Quick service feature
Improved quick recharge and graduated release features
Maximum practicable difference between service and emergency braking force

Maximum brake cylinder pressure in emergency obtained in shortest possible time

Service and emergency functions controlled by independent portions of the valve

Protection against depletion of the air system to a dangerous low point

Facility for adapting the equipment to any set of service conditions

1932—AB freight triple, with the following improvements: Service and emergency portions separated,

This department is maintained for the purpose of answering questions of members covering locomotive running and repairs, air brake equipment and diesel motive power. Only questions submitted for publication will be answered. Initials of members will be used in this connection except that should a brother so desire he may substitute a nom de plume. No attention will be paid to anonymous communications. In all cases the correct name, address and lodge number must be given by the correspondent.

will name some of the most common types. The H-6 automatic brake valve is used with No. 6-ET locomotive brake equipment and the six positions, beginning at the extreme left, are as follows: release, running, holding, lap, service, and emergency. In the following paragraphs the positions are taken up in the order in which they are most generally used.

Charging and release position: The purpose of this position is to provide a large and direct passage from the main reservoir to the brake pipe, to permit a rapid flow of air into the latter to (a) charge the train brake system, (b) quickly release, but (c) not release locomotive brakes, if they are applied.

If the handle were allowed to remain in this position the brake system would be charged to main reservoir pressure. To avoid this the handle must be moved to running or holding position. To prevent the engineman from forgetting this, a small port discharges feed valve pipe air to the atmosphere in release position with sufficient noise to attract his attention to the position in which the valve handle is standing. In this position also main reservoir air flows to the low pressure head of the compressor governor.

Running position: This is the proper position of the handle (a) when the brakes are charged and ready for use, (b) when the brakes are not being operated, and (c) to release the locomotive brakes. In this position a large direct passage is opened from the feed valve pipe to the brake pipe so that the latter will be charged as rapidly as the feed valve can supply the air, but cannot attain a pressure above that for which the feed valve is adjusted.

The equalizing reservoir charges uniformly with the brake pipe, keeping the pressure on the two sides of the equalizing piston equal. Air at present at all times above the rotary valve, passes to the low pressure head of the compressor governor. The distributing valve release pipe is connected with the atmosphere. This position gives a gradual reduction of brake pipe pressure to cause a service application. The gradual reduction is to prevent quick action. The brake pipe discharge is also gradually stopped to prevent the pressure at the head end of the brake pipe being built up by the air flowing from the rear, which might cause some of the independent brake valves in use and we

2388. Brake Valves.—"What are the different types of automatic and independent brake valves and the positions on each?"—G. D.

ANSWER.—There are many different types of automatic and independent brake valves in use and we